

SB135 Amendment to 2017 NEC section 210.12

XI. Notwithstanding the inclusion of the National Electrical Code 2017 in the state building code under RSA 155-A:1, IV, the amended provisions of section 210.12 of the National Electrical Code, which modify the National Electrical Code 2014 version to add arc-fault circuit interrupter requirements for dormitory unit devices and bathrooms, guest rooms and guest suites, and branch circuit extensions or modifications for dormitory units shall not be enforced under the state building code or this chapter.